



**NOTE**  
 INSTALL BLOW-OFF 30" BACK OF CURB FACE, AS SHOWN ON PLANS, OR AS DIRECTED BY DISTRICT INSPECTOR

**MATERIAL NOTES**

- ① RESTRAINED MJ END CAP W/ 2" FIPT TAP
- ② 2" GALVANIZED 90° "STREET" ELBOW
- ③ 2" GALVANIZED PIPE (MIPT X MIPT) X REQUIRED LENGTH
- ④ 2" BRASS GATE VALVE, (F.I.P.T X F.I.P.T.) MILWAUKEE VALVE UP105 OR APPROVED EQUAL
- ⑤ 2" PLUG
- ⑥ METER BOX No. 3 REINFORCED CONCRETE BOX, #4 CONCRETE BOX WITH TWO-PIECE POLYMER LID IF INSTALLED IN SIDEWALK
- ⑦ 14-GUAGE INSULATED COPPER LOCATING WIRE

Revised: April 22, 2020

RECOMMENDED BY:	REV.	DATE	BY
Engineering			
APPROVED BY:			
Operations			

PHELAN PIÑON HILLS  
 COMMUNITY SERVICES DISTRICT

TEMPORARY 2" BLOW-OFF ASSEMBLY



STD. DWG. No.

W-11