



SELECT MATERIAL FROM EXCAVATION

NOTE
USE AGGREGATE BASE IN TRENCHES LESS THAN 201' IN LENGTH

SEE MATERIAL NOTE No. 6

GENERAL NOTES

1. WATER PIPELINE IN WASHED OUT AREAS TO BE REPLACED WITH DUCTILE IRON PIPE WITH RESTRAINED JOINTS AND FITTINGS. NEW PIPELINE TO BE WRAPPED AND TAPED WITH 10 MIL PLASTIC
2. ALL TRENCHES SHALL BE BACKFILLED AND CONSOLIDATED IN ACCORDANCE WITH THE ABOVE DETAIL UNLESS OTHERWISE SPECIFIED BY THE PPHCSD INSPECTOR
3. UNLESS OTHERWISE INSTRUCTED BY THE PPHCSD INSPECTOR, ALL JOINTS SHALL BE VERTICAL BUTT JOINTS
4. UNLESS OTHERWISE INSTRUCTED BY THE PPHCSD INSPECTOR, TRENCH PATH SHALL BE STRAIGHT GRADE ACROSS WIDTH. CURVED PIPELINE ALIGNMENT WILL NOT BE ALLOWED.
5. WHERE TRENCH EXTENDS BEYOND THE PAVED TRAVEL LANE, AGGREGATE BASE OR SLURRY BACK FILL SHALL EXTEND 5' BEYOND EDGE OF PAVEMENT OR TO THE RIGHT-OF-WAY LINE WHICHEVER IS LESS, UNLESS OTHERWISE SPECIFIED BY THE PPHCSD INSPECTOR
6. 3-SACK 1/2" ROCK 1500 PSI MIX SAND/CEMENT SLURRY
7. FREQUENCY OF COMPACTION TESTING SHALL BE NO LESS THAN ONE TEST PER 300 LINEAL FEET OF MAIN LINE, ONE TEST MINIMUM FOR EVERY THREE (3) FEET OF VERTICAL FILL. ADDITIONAL TESTING MAY BE REQUIRED AT THE DISCRETION OF THE PPHCSD INSPECTOR

Revised: April 22, 2020

RECOMMENDED BY:	REV.	DATE	BY
Engineering			
Date			
APPROVED BY:			
Operations			
Date			

PHELAN PIÑON HILLS
COMMUNITY SERVICES DISTRICT

STANDARD WASH TRENCH REPAIR



STD. DWG. No.

W-23